




Product Service

CERTIFICATE

No. Z2 099333 0027 Rev. 02

Holder of Certificate: **LONGi Green Energy Technology Co., Ltd.**
No. 388, Middle Hangtian Road
Chang'an District
710100 Xi'an City, Shaanxi
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061718717-02

Valid until: 2024-07-17

Date, 2019-07-26

(Zhulin Zhang)



Product Service

CERTIFICATE

No. Z2 099333 0027 Rev. 02

Model(s):

LR6-72HV-xxxM (xxx=335-360, in step of 5)
LR6-60HV-xxxM (xxx=280-300, in step of 5)
LR6-72PH-xxxM (xxx=340-380, in step of 5)
LR6-60PH-xxxM (xxx=285-315, in step of 5)
LR6-72HPH-xxxM (xxx=365-395, in step of 5)
LR6-60HPH-xxxM (xxx=300-325, in step of 5)
LR6-72OPH-xxxM (xxx=385-400, in step of 5)
LR6-60OPH-xxxM (xxx=335-350, in step of 5)
LR6-72HPH-xxxMC (xxx=375-390, in step of 5)
LR6-60HPH-xxxMC (xxx=305-325, in step of 5)
LR4-72HPH-xxxM (xxx=420-440, in step of 5)
LR4-60HPH-xxxM (xxx=350-370, in step of 5)
xxx is standing for rated output power at STC.

Parameters:

Application Class:	Class A
Max. System Voltage:	1500V DC
Fire Safety Class:	Class C according to UL790.
Construction:	Framed, with Junction box, cable and connector.
Dust and Sand	
Test Method:	IEC 60068-2-68, LC1
Dust/sand Type:	95% SiO ₂
Dust /sand Concentration:	5g/m ³
Testing Air Velocity:	20m/s
Test Duration:	4h/each side.

Tested according to:

IEC 61215(ed.2)
IEC 61730-1(ed.1);am1;am2
IEC 61730-2(ed.1);am1
PPP 59022A:2013

Production Facility(ies):

002875, 001192, 090968, 099626, 099605, 099606,
096558, 097323, 102892, 103410, 103841