



Wels, August 29<sup>th</sup> 2014

## PROTECTION LIMITS FRONIUS SYMO 3.0-3-S – 20.0-3-M

**Fronius International GmbH**

hereby confirms, that the inverters

/ **Fronius Symo 3.0-3-S – 20.0-3-M**

with "Setup GR" (Greece)

are adjusted with the following grid monitoring parameters:

Parameters	Values
Grid voltage	184V – 264V
Grid frequency	49,5Hz – 50,5Hz
Tripping time	<500ms

For special requirements on the Greek islands that are not connected with the mainland grid, the inverters can be adjusted to the following grid monitoring parameters:

Parameters	Values
Grid voltage	184V – 264V
Grid frequency	47,5Hz – 51Hz
Tripping time	<500ms

### FRONIUS INTERNATIONAL GMBH

Solar Energy Division  
Froniusplatz 1  
A-4600 Wels

Ing. Prok. Martin Hackl  
Head of Solar Energy Division